

Official Laboratory Report

Report To: LOIS ELLIOT GRAHAM RS MSA
PO BOX 30817
LANSING MI 48909

Sample ID: LJ56327
Work Order: 10501618_02

System Name/Owner: ROBINSONES-2025370-1
Collection Address: 11801 120TH AVE, GRAND HAVEN
Collected By: JOANNIS NICHOLAS ROPOTOS
Township/Well#/Section: /WELL1 OR WELL 2/
County: Ottawa
Sample Point: SAMPLE TAP 006
Water System: Public System Well

WSSN/Pool ID: 2025370
Source: TYPE II
Site Code: TP001
Collector: Other
Date Collected: 05/13/2021 12:20
Date Received: 05/17/2021 11:35
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	05/18/2021		EPA 537.1	763051-92-9c
9CI-PF3ONS	Not Detected	ng/L	2	05/18/2021		EPA 537.1	756426-58-1d
ADONA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	919005-14-4e
HFPO-DA	Not Detected	ng/L	2	05/18/2021	370	EPA 537.1	13252-13-6b
NEtFOSAA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	2991-50-6
NMeFOSAA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	2355-31-9
PFBS	Not Detected	ng/L	2	05/18/2021	420	EPA 537.1	375-73-5
PFDA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	335-76-2
PFDoA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	307-55-1
PFHpA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	375-85-9
PFHxA	Not Detected	ng/L	2	05/18/2021	400000	EPA 537.1	307-24-4
PFHxS	Not Detected	ng/L	2	05/18/2021	51	EPA 537.1	355-46-4
PFNA	Not Detected	ng/L	2	05/18/2021	6	EPA 537.1	375-95-1
PFOA	Not Detected	ng/L	2	05/18/2021	8	EPA 537.1	335-67-1
PFOS	Not Detected	ng/L	2	05/18/2021	16	EPA 537.1	1763-23-1
PFTA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	376-06-7
PFTTrDA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	72629-94-8
PFUnA	Not Detected	ng/L	2	05/18/2021		EPA 537.1	2058-94-8

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Sample ID: LJ56327

Work Order: 10501618_02

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Ottawa County Health Dept.
12251 James St., Suite 200
Holland, MI 49424
616 393-5645**

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane