

Table - Lead and Copper data for Robinson Elementary School
January 2021

Sample ID	Location	Collection Date	Lead mg/L	Copper mg/L
		Action Level ^a	0.005	1.3
DW_002	Sink at Staff lounge	02/07/20	0.0013	0.39
		02/19/20	0.0014	0.34
		03/03/20	0.0021	0.084
		03/17/20	0.0025	0.15
		06/19/20	0.0032	0.17
		06/26/20	0.0029	0.26
		10/28/20	0.0011	0.58
		11/20/20	0.0014	0.51
DW_003	Kitchen 3 Compartment sink	02/07/20	0.0027	0.26
		02/19/20	0.0022	0.23
		03/03/20	0.001 U	0.19
		03/17/20	0.001 U	0.19
		06/19/20	0.0034	0.16
		06/26/20	0.0045	0.2
		10/28/20	0.001 U	0.1
		11/20/20	0.0028	0.41
DW_005	Drinking Fountain outside Boiler Room (A) - standard	02/07/20	0.052	0.41
		02/19/20	0.039	0.21
		03/03/20	0.036	0.12
		03/17/20	0.034	0.1
		6/19/2020*	0.001 U	0.025 U
		06/26/20	0.001 U	0.025 U
		10/28/20	0.001 U	0.025 U
		11/20/20	0.001 U	0.025 U
DW_005_BF	Drinking Fountain outside Boiler Room (A) - bottle fill	11/20/20	0.001 U	0.025 U
DW_006	Drinking Fountain outside Boiler Room (B) - standard	02/07/20	0.0067	0.064
		02/19/20	0.013	0.051
		03/03/20	0.08	0.27
		03/17/20	0.01	0.053
		6/19/2020*	0.001 U	0.025 U
		06/26/20	0.001 U	0.025 U
		10/28/20	0.001 U	0.025 U
		11/20/20	0.001 U	0.025 U
DW_006_BF	Drinking Fountain outside Boiler Room (B) - bottle fill	11/20/20	0.001 U	0.025 U
DW_007	Drinking Fountain outside Media Center (A) - standard	02/07/20	0.1	1.1
		02/19/20	0.076	0.74
		03/03/20	0.0025	0.35
		03/17/20	0.001 U	0.29
		6/19/2020*	0.001 U	0.039
		06/26/20	0.001 U	0.025 U
		10/28/20	0.001 U	0.025 U
		11/20/20	0.001 U	0.025 U
DW_007_BF	Drinking Fountain outside Media Center (A) - bottle fill	11/20/20	0.001 U	0.025 U
DW_008	Drinking Fountain outside Media Center (B) - standard	02/07/20	0.001 U	0.42
		02/19/20	0.001 U	0.22
		03/03/20	0.001 U	0.13
		03/17/20	0.001 U	0.076
		6/19/2020*	0.001 U	0.025 U
		06/26/20	0.001 U	0.025 U
		10/28/20	0.001 U	0.025 U
		11/20/20	0.001 U	0.025 U
DW_008_BF	Drinking Fountain outside Media Center (B) - bottle fill	11/20/20	0.001 U	0.027

Notes:

* new drinking fountain installed

U - Analyzed but not detected above the MDL

^a - MCL or TT – Lead and copper are regulated by a treatment technique that requires systems to control the corrosiveness of their water.

If more than 10% of tap water samples exceed the action level, water systems must take additional steps.

For copper, the action level is 1.3 mg/L, and for lead is 0.015 mg/L.