

Table - PFAS data for Robinson Elementary School
January 2021

Analyte	MCL ¹	2/7/2020 - First Flushing Event						2/19/2020 - Second Flushing Event					
		DW-001 Raw Water	DW-003 Kitchen 3 Compartment sink	DW-005 Drinking Fountain outside Boiler Room (A) - standard	DW-007 Drinking Fountain outside Media Center (A) - standard	DW-010 After Lead Adsorber	DW-011 After Lag Adsorber	DW-001 Raw Water	DW-003 Kitchen 3 Compartment sink	DW-005 Drinking Fountain outside Boiler Room (A) - standard	DW-007 Drinking Fountain outside Media Center (A) - standard	DW-010 After Lead Adsorber	DW-011 After Lag Adsorber
11CI-PF3OUdS	--	--	--	--	--	--	--	ND	ND	ND	ND	ND	ND
9CI-PF3ONS	--	--	--	--	--	--	--	ND	ND	ND	ND	ND	ND
ADONA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HFPO-DA	370	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-EtFOSAA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-MeFOSAA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFBS	420	17.35	ND	ND	ND	ND	ND	14.85	ND	ND	ND	ND	ND
PFDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFDoA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHpA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHxA	400,000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHxS	51	31.72	ND	ND	ND	ND	ND	34.64	ND	ND	ND	ND	ND
PFNA	6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFOA	8	4.99	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFOS	16	31.34	ND	ND	ND	ND	ND	40.58	ND	ND	ND	ND	ND
PFTeDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFTrDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFUndA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL		85.4	ND	ND	ND	ND	ND	90.07	ND	ND	ND	ND	ND

PFAS results expressed in ng/L
ND - Not detected below the limit
**New well installed and connected to the system*
1- Michigan Department of Environment, Great Lakes, and Energy (EGLE). 2020. State Drinking Water Standards under section 5 of the State Drinking Water Act, 1976 PA 299 [MCL 325.1005]. Effective August 3.
Bolded values exceed an applicable criterion or screening level.

Table - PFAS data for Robinson Elementary School
January 2021

Analyte	MCL ¹	3/3/2020 - Third Flushing Event						5/28/2020 - monthly		6/19/2020 - quartely					
		DW-001 Raw Water	DW-003 Kitchen 3 Compartment sink	DW-005 Drinking Fountain outside Boiler Room (A) - standard	DW-007 Drinking Fountain outside Media Center (A) - standard	DW-010 After Lead Adsorber	DW-011 After Lag Adsorber	DW-001 Raw Water	DW-010 After Lead Adsorber	DW-001 Raw Water	DW-003 Kitchen 3 Compartment sink	DW-005 Drinking Fountain outside Boiler Room (A) - standard	DW-007 Drinking Fountain outside Media Center (A) - standard	DW-010 After Lead Adsorber	DW-011 After Lag Adsorber
11CI-PF3OUdS	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
9CI-PF3ONS	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ADONA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HFPO-DA	370	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-EtFOSAA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-MeFOSAA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFBS	420	12.37	ND	ND	ND	ND	ND	24.91	ND	24.74	ND	ND	ND	ND	ND
PFDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFDoA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHpA	--	ND	ND	ND	ND	ND	ND	ND	ND	2.28	ND	ND	ND	ND	ND
PFHxA	400,000	ND	ND	ND	ND	ND	ND	2.57	ND	2.51	ND	ND	ND	ND	ND
PFHxS	51	32.19	ND	ND	ND	ND	ND	48.93	ND	53.52	ND	ND	ND	ND	ND
PFNA	6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFOA	8	ND	ND	ND	ND	ND	ND	6.67	ND	6.94	ND	ND	ND	ND	ND
PFOS	16	39.08	2.22	ND	ND	ND	ND	17.58	ND	24.13	ND	ND	ND	ND	ND
PFTeDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFTrDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFUndA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL		83.64	2.22	ND	ND	ND	ND	100.66	ND	114.12	ND	ND	ND	ND	ND

PFAS results expressed in ng/L

PFAS results expressed in ng/L

ND - Not detected below the limit

ND - Not detected below the limit

**New well installed and connected to t*

**New well installed and connected to the system*

1- Michigan Department of Environme

1- Michigan Department of Environment, Great Lakes, and Energy (EGLE). 2020. State Drinking Water Standards under section 5 of the State Drinking Water Act, 1976 PA 299 [MCL 325.1005]. Effective August 3.

Bolded values exceed an applicable crit

Bolded values exceed an applicable criterion or screening level.

Table - PFAS data for Robinson Elementary School
January 2021

		7/16/2020 - monthly		8/19/2020 - monthly		9/24/2020 - quartely						10/28/2020* - monthly		11/17/2020 - monthly	
Analyte	MCL ¹	DW-001 Raw Water	DW-010 After Lead Adsorber	DW-001 Raw Water	DW-010 After Lead Adsorber	DW-001 Raw Water	DW-003 Kitchen 3 Compartment sink	DW-005 Drinking Fountain outside Boiler Room (A) - standard	DW-007 Drinking Fountain outside Media Center (A) - standard	DW-010 After Lead Adsorber	DW-011 After Lag Adsorber	DW-001 Raw Water	DW-010 After Lead Adsorber	DW-001 Raw Water	DW-010 After Lead Adsorber
11CI-PF3OUdS	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
9CI-PF3ONS	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ADONA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HFPO-DA	370	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-EtFOSAA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-MeFOSAA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFBS	420	29.2	ND	23.25	ND	24.59	ND	ND	ND	ND	ND	25.22	ND	33	ND
PFDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFDoA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHpA	--	ND	ND	2.09	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFHxA	400,000	ND	ND	2.09	ND	2.12	ND	2.04	ND	ND	ND	ND	ND	ND	ND
PFHxS	51	61.09	ND	55.65	ND	46.26	ND	ND	ND	ND	ND	13.54	ND	27	ND
PFNA	6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFOA	8	5.6	ND	9.02	ND	8.15	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFOS	16	28.19	ND	20.27	ND	32.66	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFTeDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFTrDA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PFUndA	--	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL		124.08	ND	112.37	ND	113.78	ND	2.04	ND	ND	ND	38.76	ND	60	ND

PFAS results expressed in ng/L

ND - Not detected below the limit

**New well installed and connected to the system*

1- Michigan Department of Environment, Great Lakes, and Energy (EGLE). 2020. State Drinking Water Standards under section 5 of the State Drinking Water Act, 1976 PA 299 [MCL 325.1005]. Effective August 3.

Bolded values exceed an applicable criterion or screening level.

Table - PFAS data for Robinson Elementary School
January 2021

		12/24/2020 - quartely					
Analyte	MCL ¹	DW-001 Raw Water	DW-003 Kitchen 3 Compartment sink	DW-005 Drinking Fountain outside Boiler Room (A) - standard	DW-007 Drinking Fountain outside Media Center (A) - standard	DW-010 After Lead Adsorber	DW-011 After Lag Adsorber
11CI-PF3OUdS	--	ND	ND	ND	ND	ND	ND
9CI-PF3ONS	--	ND	ND	ND	ND	ND	ND
ADONA	--	ND	ND	ND	ND	ND	ND
HFPO-DA	370	ND	ND	ND	ND	ND	ND
N-EtFOSAA	--	ND	ND	ND	ND	ND	ND
N-MeFOSAA	--	ND	ND	ND	ND	ND	ND
PFBS	420	28.72	ND	ND	ND	ND	ND
PFDA	--	ND	ND	ND	ND	ND	ND
PFDoA	--	ND	ND	ND	ND	ND	ND
PFHpA	--	ND	ND	ND	ND	ND	ND
PFHxA	400,000	ND	ND	ND	ND	ND	ND
PFHxS	51	22.4	ND	ND	ND	ND	ND
PFNA	6	ND	ND	ND	ND	ND	ND
PFOA	8	ND	ND	ND	ND	ND	ND
PFOS	16	ND	ND	ND	ND	ND	ND
PFTeDA	--	ND	ND	ND	ND	ND	ND
PFTrDA	--	ND	ND	ND	ND	ND	ND
PFUndA	--	ND	ND	ND	ND	ND	ND
TOTAL		51.12	ND	ND	ND	ND	ND

PFAS results expressed in ng/L
ND - Not detected below the limit
**New well installed and connected to the system*
1- Michigan Department of Environment, Great Lakes, and Energy (EGLE). 2020. State Drinking Water Standards under section 5 of the State Drinking Water
Bolded values exceed an applicable criterion or screening level.